## **DNV·GL**

## KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS

**Object** 

Cables for general applications - Flexible cables with

1024-16

thermoplastic insulation

**Type** 

0,3/0,5 kV, 3x2,5 mm<sup>2</sup> CU/PVC/PVC H05VV-F

Rated voltage, U0/U

0,3/0,5 kV

Conductor material

Cu

Conductor cross-section

3x2,5 mm<sup>2</sup>

Insulation material

PVC

Manufacturer

Vatan Kablo

Tekirdağ/Çorlu, Turkey \*)

Client

Vatan Kablo

Tekirdağ/Çorlu, Turkey

**Tested by** 

KEMA Nederland B.V.,

Arnhem, The Netherlands

**Date of tests** 

9 October 2015 to 5 January 2016

The test object, constructed in accordance with the description, drawings and photographs incorporated in this certificate has been subjected to the series of proving tests in accordance with

## EN 50525-2-11 (2011)

This Type Test Certificate has been issued by DNV GL.

The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as listed on page 5.

This Certificate applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the Manufacturer.

\*) as declared by the manufacturer

This Certificate consists of 35 pages in total.

KEMA Nederland B.V.

P. Fonteijne

Executive Vice President

**KEMA Laboratories** 

Laboratories

Arnhem, 30 March 2016

